

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-11604 Name of Facility: Baker, George T. Aviation. Address: 3275 NW 42 Avenue City, Zip: Miami 33142 Type: Public Schools Owner: M-DCSB Food and Nutrition Person In Charge: Ciro R. Hidalgo Phone: 305-871-3143 PIC Email: cirohidalgo@dadeschools.net	Correct By: Next Inspection Re-Inspection Date: None
--	---

Inspection Information

Purpose: Routine Inspection Date: 4/12/2021	Begin Time: 08:00 AM End Time: 09:00 AM
--	--

Additional Information

FEMALES 25 MALES 1007	CENSUS	1032
--------------------------------------	--------------	------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair OUT 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation	IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL	IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other
--	--	---

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Conducted inspection with Pedro, head of facilities at location and advised Mr. Hidalgo. Inspection report emailed.

Email Address(es): cirohidalgo@dadeschools.net

Violations Comments

Violation #5. Maintenance & Repair

Black biological growth and water condensation on walls and ceiling of classroom 124. Provide insulation, repair, then clean and sanitize.

Water damaged ceiling with bubbling paint in front of elevator#2 second floor. Investigate source of water intrusion, repair, and retouch paint.

Hole in wall of classroom 202. Repair hole in wall.

Broken floor tiles in classroom 202, in front of sign indicating 004S1 at stair#4, and media center/230. Repair broken floor tiles. Building must be in good repair.

Peeling wall in classroom 202. Repair wall. Building must be in good repair.

Peeling paint on wall and ceiling in classroom 221 and classroom 123. Scrape wall and ceiling and retouch paint.

Water damaged ceiling tiles with brown biological growth and actively leaking water in portable classroom 59-169/ Portable 1. Investigate source of water intrusion, repair and then replace ceiling tiles.

Water damaged ceiling with brown biological growth on ceiling tiles in portable 2 and portable 3. Investigate the source of water intrusion, repair and then replace ceiling tiles.

Water damaged wall from wall A/C unit in portable 2. Repair leaking A/C and replace damaged wall.

Baseboard covering missing in media center room 230. Replace baseboard.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

Light not operating in classroom 210, portable 2, and portable 3. Replace light.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspector Signature:

Handwritten signature of the inspector.

Client Signature:

Handwritten signature of the client, George T. Aviation.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Kimberly Henry (913288)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Emailed to Mr. Hidalgo 4/12/21
Date: 4/12/2021

Inspector Signature:

A handwritten signature in black ink, appearing to be "K. Henry".

Client Signature:

A handwritten signature in black ink, appearing to be "George T. Baker".